

RESOLUTION No. R-2024-04

A RESOLUTION AUTHORIZING THE MAYOR AND/OR THE CITY CLERK OF THE CITY OF WARD TO ENTER INTO A CONTRACT TO PURCHASE THREE (3) 10-HORSEPOWER PUMP FOR VARIOUS WASTEWATER LIFT STATIONS

WHEREAS, A.C.A. 14-235-203, states that “every municipality in the State of Arkansas is authorized and empowered to own, acquire, construct, equip, operate, and maintain, within or without the corporate limits of the city or town, a sewage collection system or a sewage treatment plant, intercepting sewers, outfall sewers, force mains, pumping stations, ejector stations, and all other appurtenances necessary or useful and convenient for the collection and treatment, purification, and disposal in a sanitary manner of the liquid and solid waste, sewage, night soil, and industrial waste of the municipality”; and,

WHEREAS, from time to time, it becomes necessary to replace pumps and other appurtenances to maintain an effective wastewater collection system; and,

WHEREAS, the City of Ward Wastewater System needs to purchase three (3) 10-horsepower pump to replace three (3) pumps that are beginning to fail; and,

WHEREAS, per Ward Ordinance O-2022-02, Section 2(b), only one (1) bid was obtained because of the need to ensure like pumps are purchased, our history with the company, and the need to expedite the order.

NOW, THEREFORE, IT IS RESOLVED THAT THE CITY COUNCIL OF THE CITY OF WARD hereby declares that the Mayor or the City Clerk may enter into a contract with **J.R. Stewart Pump & Systems** to purchase three (3) Barnes brand four-inch, 10-horsepower, 1750 RPM, 460 volt, 3-phase pumps. Further, the bid by said Contractor (attached) is hereby accepted in the amount of **\$29,560.65** (includes shipping) plus applicable tax.

SAID RESOLUTION WAS ADOPTED ON 01-19-2024

Brooke Yes, Chapman Yes, Hall Yes, Hefner Absent, McMinn Yes, Ruble Yes


YEAS: 5 NAYS: 0 Mayor (if needed) _____

APPROVED:

ATTEST:



Charles Gastineau, Mayor



Krystal Rummel, City Clerk



JRSPUMP, INC

313 S. 2nd St West Memphis AR 72301

Office; 870-735-2484

Cell 901-461-7603

Quotation Date 1/18/2024

Company Name J.R. STEWART PUMP&EQUIP
INC.

Customer Code JRS0100

Prepared By Patrick Hughey

Contact Bruce Jones
City of ward

RSM KURT ROGERS

Lead Time 4 to 6 weeks

937-214-8791

Freight Freight allowed,
Tax Not included

krogers@cranepumps.com

Item	Description	Qty	Net Each	Total Net
1	148175-MBM - Barnes 4ESCDG100N4, Vertical Dry Pit, 4 inch discharge, hydraulic series DG, 10 HP, 1750 rpm, 460 volts, 3 phase, impeller trimmed to 210mm, Impeller Material Ductile Iron, Carbon / Sil Car Upper, Sil Car / Sil Car Lower seal, Explosion Proof = N, 5 Year Full Warranty from Shipment	3	\$9,853.55	\$29,560.65
Total:				\$29,560.65

BARNES **burks** **DEMING** **WEINMAN**  **PROSSER**